



13501-1 Classification Rating	1716 PCS max	EN ISO 11925-2	13823												
			FIGRA	THR	SMOGRA			TSP							
					s1	s2	s3	s1	s2	s3	d0	d1	d2		
A1	2.0 MJ/KG	N/A	≤ 20 W/s	≤ 4.0 MJ	≤ 30 m <sup>2</sup> /S <sup>2</sup>	N/A	N/A	No performance declared	≤ 50 m <sup>2</sup>	< 200 m <sup>2</sup>	No performance declared	No flaming droplets / particles occur within 600 s	No flaming droplets / particles, persisting longer than 10 s, occur within 600 s	No performance is declared or a) does not meet d0 or d1 criteria or the paper in the 11925-2 test ignites	
A2	3.0 MJ/KG	N/A	No lateral spread and ≤ 120 W/s	≤ 7.5 MJ											
B	N/A	Less than 150mm flame spread in 15 seconds after 20 seconds ATRT	No lateral spread and ≤ 120 W/s	≤ 7.5 MJ											
C	N/A		No lateral spread and ≤ 250 W/s	≤ 15 MJ											
D	N/A		≤ 750 W/s	N/A											
E	N/A	Less than 150mm flame spread in 15 seconds after 20 seconds ATRT	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	The paper in the 11925-2 test ignites	
F	N/A	Failed to meet class E or no performance declared	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A